Enclosure: VII.F.

THE GROSSE POINTE PUBLIC SCHOOL SYSTEM Grosse Pointe, Michigan

AGENDA NUMBER & TITLE: VII.F. Approval of North Chiller

BACKGROUND INFORMATION:

On June 3, 2021 we held a public bid opening for proposals received to replace a chiller compressor variable frequency drive at North High School. A post bid interview was conducted to ensure the appropriate scope of work was included in the bid and there were no errors or omissions.

The project includes:

- Removal of existing damaged unit
- Install new air-cooled Variable Frequency Drive (VFD) in new cabinet
- Install disconnect, control transformer, and VFD controller
- Inspect and verify chiller operation

One contractor submitted a proposal. Our recommendation is to award the project to Thermal-Netics, Inc. (Daiken Applied) at a cost of \$65,920 plus contingency of \$6,592 for a not to exceed cost of \$72,512.

REQUEST:

The Board of Education approve the contract award for the North chiller replacement to Thermal-Netics, Inc. (Daiken Applied) at a cost of \$65,920 plus contingency of \$6,592 for a not to exceed cost of \$72,512.

| | Funding Source | |
|----------------|----------------|----------------|
| ☐ General Fund | ☐ Bond Fund | ✓ Sinking Fund |

Amanda Matheson Deputy Superintendent for Business Operations



BID TABULATION

June 3, 2021

Grosse Pointe Public Schools System GPN Chiller Compressor VFD Replacement Project No. 1921

| Contractor | Familial Disclosure Y/N | Iran Economic Sanctions Act Y/N | Non- Discrimination in Employment Y/N | Certification of Non- Segregated Facilities Y/N | Contractor Notification Form for New or Renovation Work Y/N | Asbestos-Free Certification Y/N | Non-Collusive Affidavit Y/N | Bid Bond Y/N | Base Proposal Amount | Bid order |
|---------------------------------------|----------------------------|---------------------------------------|--|--|---|---------------------------------------|--------------------------------|--------------|-------------------------|-----------|
| | | | | | | | | | | |
| Thermal-Netics, Inc. (Daiken Applied) | Y | Y | Υ | Υ | N/A | Υ | Y | Y | \$65,920.00 | |
| | | | | | | | | | | |
| | | | | | | | | | | |
| | | | | | | | | | | |
| | | | | | | | | | | |
| | | | | | | | | | | |
| | | | | | | | | | | |
| | | | | | | | | | | |
| | | | | | | | | | | |
| | | | | | | | | | | |
| | | | | | | | | | | |
| | | | | | | | | | | |
| | | | | | | | | | | |
| | | | | | | | | | | |
| | | | | | | | | | | |
| | | | | | | | | | | |
| | | | | | | | | | | |
| | | | | | | | | | | |
| | | | | | | | | | | |
| | | | | | | | | | | |
| | | | | | | | | | | |